

**ST LANDRY WWD 3 PORT BARRE AREA D**

**Public Water Supply ID: LA1097037**

**Consumer Confidence Report**

# 2024 CCR

**Additional Information and Electronic Copies can be found at  
[www.ldh.la.gov/ccr](http://www.ldh.la.gov/ccr)**

What you need to do:

Review base report (numbered pages) for errors. If you are a surface water system, you must insert the turbidity data.

Distribute completed report to your customers as outlined on the CCR Certification of Distribution Form no later than June 30, 2025.

A completed CCR Certification of Distribution Form including a copy of the final CCR report should be submitted to the State at the address provided on the form no later than September 30, 2025.

**If submitting CCR Electronically by posting on a website, be aware of LAC 51:XII.403.C – Community water systems shall include their final letter grade and score in their annual Consumer Confidence Report (a.k.a. Annual Water Quality Report) that is posted on the water system website. A statement like below must be added to the CCR notifying consumers of the water system grade.**

Our water system grade is an “A”. Our water system report card can be found at [www.ldh.la.gov/ccr](http://www.ldh.la.gov/ccr).

**UCMR5-Water systems are required to distribute results for the unregulated contaminant-monitoring rule (UCMR). If you have collected samples and received results, you may insert that data into the CCR to satisfy the notification requirement. The average of all results and the range of results at with the contaminant was detected.**

**Notes:**

This page is not part of your CCR; it is only the instruction page. The pages that are numbered in the upper right hand corner are the report pages.

This page intentionally left blank

# The Water We Drink

## ST LANDRY WWD 3 PORT BARRE AREA D

Public Water Supply ID: LA1097037

We are pleased to present to you the Annual Water Quality Report for the year 2024. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water system purchases water as listed below:

Buyer Name	Seller Name
LA1097037 - ST LANDRY WWD 3 PORT BARRE AREA D	TOWN OF LEONVILLE WATER SYSTEM
LA1097037 - ST LANDRY WWD 3 PORT BARRE AREA D	TOWN OF PORT BARRE WATER SYSTEM

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants – which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact Lauren Hardy at 337-585-3796.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who is exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood

pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Treatment Technique (TT) – an enforceable procedure or level of technological performance, which public water systems must follow to ensure control of a contaminant.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 assessment – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

During the period covered by this report we had the below noted violations.

Compliance Period	Analyze	Type
4/30/2024 - 5/30/2024	CHLORINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)
5/20/2024 - 7/8/2024	CHLORINE	RESIDUAL NOT MONITORED MRT-POE-ACR (GW)
6/30/2024 - 7/30/2024	CHLORINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)
7/31/2024 - 8/30/2024	CHLORINE	5% DS BELOW MIN 0.5-2 MONTHS CONSEC(GW)

7/31/2024 - 8/30/2024	CHLORINE	INADEQUATE MIN CHLORINE RESIDUAL(GW&SW)
-----------------------	----------	--

Our water system tested a minimum of 2 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	HighestRAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2024	1.4	ppm	0.63 - 1.83	4	4	Water additive used to control microbes

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	11/26/2023	TOWN OF LEONVILLE WATER SYSTEM	0.55	0.27 - 0.55	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
BARIUM	8/13/2023	TOWN OF PORT BARRE WATER SYSTEM	0.31	0.25 - 0.31	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DI(2-ETHYLHEXYL) ADIPATE	8/13/2023	TOWN OF PORT BARRE WATER SYSTEM	0.47	0 - 0.47	ppb	400	400	Discharge from chemical factories
FLUORIDE	11/26/2023	TOWN OF LEONVILLE WATER SYSTEM	0.3	0.3	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
FLUORIDE	8/13/2023	TOWN OF PORT BARRE WATER SYSTEM	0.2	0.2	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	10/21/2024	TOWN OF LEONVILLE WATER SYSTEM	0.2	0 - 0.2	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	4/28/2024	TOWN OF PORT BARRE WATER SYSTEM	0.1	0.1	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM	11/26/2023	0.869	0 - 0.869	pCi/l	5	0	Erosion of natural deposits

(-226 & -228)							
COMBINED RADIUM (-226 & -228)	8/13/2023	1.48	1.03 - 1.48	pCi/l	5	0	Erosion of natural deposits
GROSS ALPHA PARTICLE ACTIVITY	11/26/2023	7.33	0 - 7.33	pCi/l	15	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	11/26/2023	3.49	2.52 - 3.49	pCi/l	50	0	Decay of natural and man-made deposits.
GROSS BETA PARTICLE ACTIVITY	8/13/2023	2.46	1.81 - 2.46	pCi/l	50	0	Decay of natural and man-made deposits.
RADIUM-226	11/26/2023	0.638	0 - 0.638	PCI/L	5	0	Erosion of natural deposits
RADIUM-228	11/26/2023	0.869	0 - 0.869	PCI/L	5	0	Erosion of natural deposits
RADIUM-228	8/13/2023	1.48	1.03 - 1.48	PCI/L	5	0	Erosion of natural deposits

Lead and Copper	Date	90TH Percentile	Range	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2024	0	0 - 0.4	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2024	0	0 - 1	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	EAST OF 2 O'CLOCK BAYOU	2023 - 2024	11	8.8 - 11.9	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	HWY 190 AND PERNIE BAILEY ROAD	2023 - 2024	8	6.4 - 8.9	ppb	60	0	By-product of drinking water disinfection
TTHM	EAST OF 2 O'CLOCK BAYOU	2023 - 2024	35	28.2 - 35.7	ppb	80	0	By-product of drinking water chlorination
TTHM	HWY 190 AND PERNIE BAILEY ROAD	2023 - 2024	23	20.2 - 25.2	ppb	80	0	By-product of drinking water chlorination

Source Secondary Contaminants	Water System	Collection Date	Highest Value	Range	Unit	SMCL
ALUMINUM	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	0.04	0.03 - 0.04	MG/L	0.2
ALUMINUM	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	0.04	0.03 - 0.04	MG/L	0.2
CHLORIDE	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	240	14 - 240	MG/L	250
CHLORIDE	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	32	0 - 32	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	120.6	65.8 - 120.6	MG/L	0

HARDNESS, TOTAL (AS CaCO3)	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	146.9	136.4 - 146.9	MG/L	0
IRON	TOWN OF LEONVILLE WATER SYSTEM	10/21/2024	1.4	0.35 - 1.4	MG/L	0.3
IRON	TOWN OF PORT BARRE WATER SYSTEM	4/28/2024	0.81	0.81	MG/L	0.3
MANGANESE	TOWN OF LEONVILLE WATER SYSTEM	10/21/2024	0.1	0.06 - 0.1	MG/L	0.05
MANGANESE	TOWN OF PORT BARRE WATER SYSTEM	4/28/2024	0.11	0.11	MG/L	0.05
PH	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	6.34	5.94 - 6.34	PH	8.5
PH	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	6.33	6.24 - 6.33	PH	8.5
POTASSIUM	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	3.7	2.4 - 3.7	MG/L	0
POTASSIUM	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	2.3	2 - 2.3	MG/L	0
SODIUM	TOWN OF LEONVILLE WATER SYSTEM	11/26/2023	211	83 - 211	MG/L	0
SODIUM	TOWN OF PORT BARRE WATER SYSTEM	8/13/2023	36.9	30.2 - 36.9	MG/L	0

+++++Environmental Protection Agency Required Health Effects Language+++++

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ST LANDRY WWD 3 PORT BARRE AREA D is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact ST LANDRY WWD 3 PORT BARRE AREA D and Lauren Hardy at Phone: 337-585-3796. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

There are no additional required health effects notices.

There are no additional required health effects violation notices.

+++++

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at the ST LANDRY WWD 3 PORT BARRE AREA D work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children's future. Additional information on the water system can be found at [www.ldh.la.gov/watergrade](http://www.ldh.la.gov/watergrade). Please call our office if you have questions.